

GENERAL NOTES:

- 1. THE 3% CEMENT TREATED C.R SHALL BE LAID WITHIN 15 MINUTES UPON ARRIVAL TO SITE. IT SHALL BE 4% ABOVE OPTIMUM MOISTURE CONTENT.
- 2. SUBGRADE TO BE GRADED AND ROLLED TO ENGINEERS SATISFACTION PRIOR LAYING THE STABILIZED LAYER.
- 3. EXPANSION JOINTS ARE REQUIRED AROUND POLES, MANHOLES AND OTHER SERVICE AUTHORITY FIXTURES.
- 4. TRANSVERSE JOINTS, CONSTRUCTION JOINTS, SAWCUT JOINTS, LONGITUDINAL JOINTS AND ISOLATION JOINTS TO BE CONSTRUCTED AS PER STANDARD DETAIL.
- 5. ENGINEER TO SPECIFY SPACINGS FOR JOINTS SPECIFIED IN NOTE 4(ABOVE).
- 6. CHAIRS TO BE USED TO SUPPORT F92 MESH
- 7. A ROUGH BROOMED FINISH IS REQUIRED TO THE ENGINEERS REQUIREMENTS.
- 8. MINIMUM LONGITUDINAL GRADE OF R.O.W. TO BE 0.3%
- 9. CHANNEL TO BE CONSTRUCTED SEPERATELY TO 200mm CONCRETE PAVEMENT. PAVEMENT TO BE CONNECTED TO CHANNEL VIA DEFORMED BARS AS SPECIFIED.

Yarra Standard: YSD505 Drawing Title:

CONCRETE RIGHT OF WAY

Scale at A4 N.T.S			9.2
REV	DATE	DRAWN BY	
Α	27/11/07	HL	
В	30/04/12	DKC	
С	04/10/13	OK	
			CITY OF
			V ₂ DD A
			I IAKKA
Richmond Town Hall 333 Bridge Road Richmond PO Box 168 Richmond 3121 Phone (03) 9205 5010 Fax (03) 8417 6666			