EXCAVATE EXISTING SURFACE TO MIN. 150mm BELOW FINISHED SURFACE LEVELS AND CONSTRUCT CONCRETE PATHWAY WITH: - 100mm THICK N25 REINFORCED CONCRETE SLAB (F42 PLACED CENTRALLY) - 50mm OF COMPACTED CRUSHED ROCK (CLASS 2) - BUILD UP WITH APPROVED COMPACTED SUBSOIL (WHERE NECESSARY) **VARIES** 2% FALL OR CROSSFALL - SUB-SOIL Yarra Standard: YSD513 Drawing Title: Concrete Path - Pedestrian Scale at A4 1: 10 REV DATE DRAWN BY A 06/09/02 DKC B 30/04/12 Richmond Town Hall 333 Bridge Road Richmond PO Box 168 Richmond 3121 Phone (03) 9205 5085 Fax (03) 9205 5069