



**GENERAL NOTES**

1. ALL CONCRETE SHALL BE F'c 25 MPa AT 28 DAYS
2. BRICKS TO BE REMOVED USING SAW CUTTING TOOLS.
3. PIT DEEPER THAN 750mm SHALL BE FITTED WITH GALVANISED STEP IRONS @ 300mm C.T.S. REFER TO DRAWING YSD212 FOR DETAILS.
4. PIT REINFORCEMENT DETAILS ARE SHOWN IN TABLE. FABRIC IN SHAFT SHALL HAVE THE MAIN BARS POSITIONED HORIZONTALLY. LAPS TO BE 300mm MIN. CORNER RETURN REINFORCEMENT MAY BE FABRIC OR EQUIVALENT BARS. BARS GRADE 400Y & FABRICS TO COMPLY WITH AS/NZS 4671 CONCRETE SHALL BE NORMAL -CLASS N32 STANDARD STRENGTH GRADE OR HIGHER COMPLYING WITH THE REQUIREMENTS OF AS1379.
5. WORKS IN CONFINED SPACE TO BE IN ACCORDANCE WITH THE CURRENT VICTORIAN ACT, THE OH&S (CONFINED SPACE) REGULATIONS AND THE CODE OF PRACTICE FOR CONFINED SPACES.

**REINFORCEMENT DETAILS**

PIT LENGTH "L"	REINFORCEMENT
UP TO 1200	F92
1201 TO 1800	F918
1801 TO 2400	F1218

**Yarra Standard: YSD202**  
**Drawing Title:**  
 JUNCTION PIT DETAILS

Scale at A4 N.T.S

REV	DATE	DRAWN BY
A	29/11/07	HL
B	30/04/12	DKC
C	5/02/14	HL
D	25/05/15	HL
E	22/12/15	HL

